

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Rechargeable Li-ion battery System

Name and address of the applicant

Jiangsu Oliter Energy Technology Co., Ltd.
No.88 Bosideng Road Gaoyou Economic Development Zone, Yangzhou,
Jiangsu, China

Name and address of the manufacturer

Jiangsu Oliter Energy Technology Co., Ltd.
No.88 Bosideng Road Gaoyou Economic Development Zone, Yangzhou,
Jiangsu, China


Name and address of the factory

Jiangsu Oliter Energy Technology Co., Ltd.
No.88 Bosideng Road Gaoyou Economic Development Zone, Yangzhou,
Jiangsu, China*When more than one factory*☐ Additional information on page 2

Ratings and principal characteristics

Product data – type OHR100.3K-280Nominal Energy: 100,3 kWh; Nominal Voltage: 358,4 Vdc; Voltage Range:
324,8 Vdc to 397,6 Vdc**Product data – type OHR114.6K-280**Nominal Energy: 114,6 kWh; Nominal Voltage: 409,6 Vdc; Voltage Range:
371,2 Vdc to 454,4 Vdc**Product data – type OHR129.0K-280**Nominal Energy: 129 kWh; Nominal Voltage: 460,8 Vdc; Voltage Range:
417,6 Vdc to 511,2 Vdc**Product data – type OHR143.3K-280**Nominal Energy: 143,3 kWh; Nominal Voltage: 512 Vdc; Voltage Range:
464,0 Vdc to 568,0 Vdc**Product data – type OHR157.6K-280**Nominal Energy: 157,6 kWh; Nominal Voltage: 563,2 Vdc; Voltage Range:
510,4 Vdc to 624,8 Vdc**Product data – type OHR172.0K-280**Nominal Energy: 172 kWh; Nominal Voltage: 614,4 Vdc; Voltage Range:
556,8 Vdc to 681,6Vdc**Product data – type OHR186.3K-280**Nominal Energy: 186,3 kWh; Nominal Voltage: 665,6 Vdc; Voltage Range:
603,2 Vdc to 738,4 Vdc**Product data – type OHR200.7K-280**Nominal Energy: 200,7 kWh; Nominal Voltage: 716,8 Vdc; Voltage Range:
649,6 Vdc to 795,2 Vdc**Product data – type OHR215.0K-280**Nominal Energy: 215 kWh; Nominal Voltage: 768 Vdc; Voltage Range:
696,0 Vdc to 852,0 Vdc**Product data – type OHR43.0K-280**

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051
6825 MJ Arnhem
Netherlands

Date: 2024-12-26

Signature: Miranda Zhou

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

Nominal Energy: 43 kWh; Nominal Voltage: 153,6 Vdc; Voltage Range:
139,2 Vdc to 170,4 Vdc

Product data – type OHR57.3K-280

Nominal Energy: 57,3 kWh; Nominal Voltage: 204,8 Vdc; Voltage Range:
185,6 Vdc to 227,2 Vdc

Product data – type OHR71.6K-280

Nominal Energy: 71,6 kWh; Nominal Voltage: 256 Vdc; Voltage Range:
232,0 Vdc to 284,0 Vdc

Product data – type OHR86.0K-280

Nominal Energy: 86 kWh; Nominal Voltage: 307,2 Vdc; Voltage Range:
278,4 Vdc to 340,8Vdc

Trademark / Brand (if any)


OLITERCustomer's Testing Facility (CTF) Stage
used

Model / Type Ref.

OHR100.3K-280, OHR114.6K-280, OHR129.0K-280, OHR143.3K-280,
OHR157.6K-280, OHR172.0K-280, OHR186.3K-280, OHR200.7K-280,
OHR215.0K-280, OHR43.0K-280, OHR57.3K-280, OHR71.6K-280 and
OHR86.0K-280

Additional information

☐ Additional information on page 2

A sample of the product was tested and
found to be in conformity with
As shown in the Test Report Ref. No.
which forms part of this Certificate

IEC 62619:2022

6198159.50

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051
6825 MJ Arnhem
Netherlands

Date: 2024-12-26


Signature: Miranda Zhou